


30-POINT INSPECTION CHECKLIST

Urgent Requirements For Essential Door And Dock Maintenance



1 OPERATIONAL WORKFLOW

- Door sensors operate smoothly during open-close cycles
- Tracks are level, plumb, and anchored correctly
- Drive chains show no clear signs of excessive wear
- Belts and bearings are in good working condition
- Fluids are at proper levels and without leakage



2 EQUIPMENT INTEGRITY

- Guides and frames are secure, straight, and undamaged
- Hinges, rollers, and springs are balanced and lubricated
- Curtains, sections, and slats are free of wear and corrosion
- Weld points show no clear signs of cracking or breakage
- Hydraulic cylinder valves and hoses are undamaged



3 SAFETY / EHS

- Hoods and covers are in good condition and not interfering
- Safety edges and devices stop and reverse properly
- Wiring is properly installed and in good working condition
- Weather seals are undamaged and provide full coverage
- Emergency and chain hoist releases function correctly




4 SECURITY

- Sensors and activation devices function properly
- Operators are secure with no loose bolts or anchors
- All locks function properly and operate with ease
- Dock leveler curb angles are properly embedded
- Control panels function correctly and are properly sealed



5 FIRE STANDARDS

- No open holes or breaks on door and frame surfaces
- Automatic release is fully operational from open position
- All associated parts are from original door manufacturer
- Closed door is secured by operator and latching hardware
- Glazing and vision frames are fastened in place and intact



6 SANITATION

- Touchless devices easily detect motion within range
- Touchless activation is in compliance with ANSI standards
- Enclosures correspond with application requirements
- Actuator wiring is undamaged and properly installed
- Washdown control panels adhere to NEMA 4 rating